

The main equation that we solve for the design of a geothermal loop length and well depth is listed below. This equation and the following pages are a part of the approximately 1,000 page calculation and report for this 96 unit, 107 ton housing project in Vancouver, BC, Canada.

$$L_h = \frac{q_a \times R_{ga} + (q_{lh} - 3.41 \times \overline{W}_h) (R_b + PLF_m R_{gm} + R_{gd} \times F_{sc})}{t_g - \frac{t_{wi} + t_{wo}}{2} - t_p}$$

Where,

- $F_{sc}$  = short-circuit heat loss factor
- $L_h$  = required bore length for heating (ft)
- $PLF_m$  = part-load factor during design month
- $q_a$  = net annual average heat transfer to the ground (Btu/h)
- $q_{lh}$  = building design heating block load (Btu/h)
- $R_{ga}$  = effective thermal resistance of the ground, annual pulse (hr \* ft\*°F / Btu)
- $R_{gd}$  = effective thermal resistance of the ground, daily pulse (h \* ft\*°F / Btu)
- $R_{gm}$  = effective thermal resistance of the ground, monthly pulse (h \* ft\*°F / Btu)
- $R_b$  = thermal resistance of bore (h \* ft\*°F / Btu)
- $t_g$  = undisturbed ground temperature (°F)
- $t_p$  = temperature penalty for interference of adjacent bores (°F)
- $t_{wi}$  = liquid temperature at heat pump inlet (°F)
- $t_{wo}$  = liquid temperature at heat pump outlet (°F)
- $W_h$  = power input at design heating load (W)

The reference for this equation is, "Ground-Source Heat Pumps, Design of Geothermal Systems for Commercial and Institutional buildings", Stephen P. Kavanaugh, Kevin Rafferty, ASHRAE, 1997, page 23, and ASHRAE Short Course, "Design of Commercial Ground-Source Heat Pumps, January 29, 2001, Atlanta, GA.

Summary of all House calculations for Mole Hill Housing, Vancouver, BC, Canada,

MOLE HILL									
8-Jan-02									
GEOTHERMAL SYSTEMS									
Hse #	Area Sq.Ft.	Unit Cap. Tons	Act. Bore Feet	Calc.Load Btu/Hr	Calc.Bore Feet	Units Connected	Combined Actual	Combined Calculated	Conclusion
11	6910	10	1500	145405	1204	a			
12	2922	5	750	78951	676	a	2250	1880	OK
13	3703	5	750	98266	905	b			
14	2818	5	750	66188	525	b	1500	1430	OK
15	4341	6	900	96577	847	c			
16	4674	6	900	100431	893	c			
17	4787	6	900	113904	1052	c	2700	2792	OK
18	4429	6	900	97878	862	d			
19	3001	6	900	95188	831	d			
20	3746	6	900	85871	720	d	2700	2413	OK
21	7153	10	1500	147504	1229	e	1500	1229	OK
22a	4524	6	900	96969	852	f			
22b	5047	7.5	1125	100942	862	f	2025	1714	OK
23	3234	5	750	88629	791	g			
24	4775	7.5	1125	114522	1023	g	1875	1814	OK
25	3212	5	750	78071	666	h			
26	3486	5	750	78418	670	h	1500	1336	OK

107 Tons

16,050 feet

72 wells

223 feet average

The following is a sample bore hole length calculation for Mole Hill Housing, Vancouver, BC, Canada, House 11,

Ground Source Heat Pumps			Building H11		8-Jan-02	
Symbol	Descript.	Init. Entry	Calcs 1	Calcs 2	Bore Length	
					Actual	1500
$q_a$	gd hl	55.00	$q_a \times R_{ga}$			
$R_{ga}$	r gd	0.33	18.1500[1]			
$q_{th}$	bldg hl	145405.00	$q_{th} \times W_h$			
$W_h$	pwr input	43920.80	101484.20[2]			
$R_p$	r pipe	0.11				
PLF <sub>m</sub>	part load	30.00				
$R_{gm}$	r gd	0.327				
$R_{gd}$	r gd	0.23	$R_p + ((PLF_m \times R_{gm}) + (R_{gd} \times F_{sc}))$	1 + (2 x 3)	4 divided by 5	
$F_{sc}$	sht.circ.	0	9.92[3]	10232.09[4]	1204	
$t_g$	t grd	54.00				
$t_{wi}$	t liquid in	43.00				
$t_{wo}$	t liquid out	48.00				
$t_p$	int. penalty	0.00			$t_g - (t_{mi} + t_{mo})/2 - t_p$	8.50[5]
$q_a$	gd hl				Ht.trans.from gd.	
$R_{ga}$	r gd				R ground annual	
$q_{th}$	bldg hl				Bldg.heat loss	
$W_h$	pwr input				Power input	
$R_p$	r pipe				R pipe	
PLF <sub>m</sub>	part load				Part load factor	
$R_{gm}$	r gd				R ground daily	
$R_{gd}$	r gd				R ground monthly	
$F_{sc}$	sht.circ.				Short circuit factor	
$t_g$	t grd				Ground temp.	
$t_{wi}$	t liquid in				Temp to HP	
$t_{wo}$	t liquid out				Temp from HP	
$t_p$	int. penalty				Interference factor	

Equivalent Thermal Resistance

1	3650 days		
2	3650 + 30 days		
f	3650 + 30 + 0.167 days		
$k_g$	1.3 btu/hr/ft/deg.F		
$a_g$	0.75 ft <sup>2</sup> /day		
$d_{equ}$	0.18 ft		
$Fo_f$	$4 \times 0.75 \times 3680.167 / 0.0324 =$	340756.00	$G_1 1.1500$
$Fo_1$	$4 \times 0.75 \times 30.167 / 0.0324 =$	2793.00	$G_1 0.0725$
$Fo_2$	$4 \times 0.75 \times 0.167 / 0.0324 =$	15.50	$G_2 0.3000$
$R_{ga}$	$(1.15 - 0.725) / 1.3$	=0.330	
$R_{gm}$	$(0.725 - 0.30) / 1.3$	=0.327	
$R_{gd}$	$0.30 / 1.3$	=0.230	